
Accreditation to Technical Criteria

Emergency Lighting Systems

Classification in this category is intended for those enterprises undertaking the installation of emergency lighting systems. Classification in this category may be achieved if the enterprise:

- Has publications and documentation appropriate to the range and scale of work undertaken which must include the following:
 - a) BS 5266-1: 2005, Emergency Lighting - Code of practice for the emergency lighting of premises.
 - b) BS 5266-8: 2004 (BS EN 50172: 2004) Emergency Escape Lighting Systems.
- Additional appropriate documentation may include BS 5266-7: 1999 (BS EN 1838: 1999) as amended, Lighting Applications – Emergency Lighting.
- Will undertake that all work is carried out by competent persons to a standard not less than that laid down in BS 5266 including appropriate verification and shall conform with the requirements of BS 7671 and the Electricity at Work Regulations 1989.
 - Has at least one nominated competent person who has the necessary skills and experience to carry out the work to the appropriate standards and meets the 9 requirements for a nominated Qualified Supervisor in work category 3.1 for Low and Extra-low Voltage Electrical Installations up to 1kV.