
Accreditation to Technical Criteria

Fire Detection and Fire Alarm Systems in Dwellings only

Classification in this category is intended for those enterprises undertaking the installation of fire detection and fire alarm systems only in dwellings.

Classification in this category may be achieved if the enterprise:

- Has publications and documentation appropriate to the range and scale of work undertaken which may include BS 5839-6: 2004 as amended, Fire detection and fire alarm systems for buildings - Code of practice for the design, installation and maintenance of fire detection and fire alarm systems in dwellings.
- Will undertake that all work is carried out by competent persons to a standard not less than that laid down in BS 5839-6 including appropriate verification and shall conform with the requirements of BS 7671 and the Electricity at Work Regulations 1989.
- Has at least one nominated competent person who has the necessary skills and experience to carry out the work and meets the requirements for a nominated Qualified Supervisor in work category - Low and Extra-low Voltage Electrical Installations up to 1kV.